

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT

| | | |
|---|--------------------------|--------------------------------------|
| Name & Address of Customer : S.A.V. Jain Day Boarding School Una Road, Hoshiarpur | Customer Reference No. | No : SAV/10252 Dated : 13/02/2026 |
| | Sample Submitted by | Pawan Kumar |
| | Date of Sample Receipt | 14/02/2026 |
| | Analysis Starting Date | 14/02/2026 |
| | Analysis completion Date | 16/02/2026 |
| Discipline : Chemical Testing, Bacteriological Testing | Group: Water | |
| UI R No.: | Sample Type : | Water |
| Test Report No.: RWTLHSP/2526/00762 | Date of Issue : | 16/02/2026 |
| Registration no.: RWTLHSP/REG2526/04816 | Condition of Sample : | Unsealed |
| Collection Point: Treatment Plant (RO/CWPP/ARP/HH Purifier) | Quantity/Type of Bottle: | 1000 ml / Transparent Plastic Bottle |
| Scheme/Source: Not Mentioned(Not Mentioned) | Location/Depth : | S.A.V. Jain Day Boarding School / NA |
| Village : Not Mentioned | Habitation : | Not Mentioned |
| Block: Hoshiarpur-II | District : | Hoshiarpur |
| Latitude : Not Mentioned | Longitude: | Not Mentioned |

| Sr. No | Parameter | Result | As per IS-10500:2012 (2nd Rev.) | | Unit | Reference Method : |
|--------|----------------------|---------------|--|-------------------|-------------|---|
| | | | Acceptable Limit | Permissible Limit | | |
| 1 | pH | 7.51@25°C | 6.5-8.5 | No Relaxation | -- | IS 3025 (Part 11-2022) Electrometric Method |
| 2 | Colour | 1 | 5 | 15 | CU | IS 3025(Part 4-2021) Visual Comparison Method |
| 3 | Odour | Agreeable | Agreeable | Agreeable | -- | IS 3025 (Part 5 -- 2018) (Second Revision) |
| 4 | Taste | Agreeable | Agreeable | Agreeable | -- | IS 3025 (Part 8 -- 2023) |
| 5 | TDS | 344.0 | 500 | 2000 | mg/l | IS 3025 (Part 16-2023) Gravimetric Method |
| 6 | Turbidity | BDI | 1 | 5 | NTU | IS 3025 (Part 10-2023) Nephelometric Method |
| 7 | T. Alkalinity(CaCO3) | 282.8 | 200 | 600 | mg/l | IS 3025 (Part 23-2023) Indicator Method |
| 8 | T. Hardness(CaCO3) | 246.44 | 200 | 600 | mg/l | IS 3025 (Part 21- 2009)(RA 2023) EDTA Method |
| 9 | Calcium(Ca) | 51.82 | 75 | 200 | mg/l | IS 3025 (Part 40-2024) EDTA Titrimetric Method |
| 10 | Magnesium(Mg) | 28.47 | 30 | 100 | mg/l | APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method |
| 11 | Chloride(Cl) | 22.15 | 250 | 1000 | mg/l | IS 3025 (Part 32-1988) Argentometric Method |
| 12 | Total Coliform(TC) | ND | Shall not be detectable in any 100 ml sample | No relaxation | MPN/100 ml. | IS-1622 MPN Method |
| 13 | E-Coli | ND | Shall not be detectable in any 100 ml sample | No relaxation | MPN/100 ml. | IS-1622 MPN Method |

Continue on next page...

Reviewed and Approved By


Abhishek Joshi
 Sr. Chemist
 Authorized Signatory
 For, Regional Water Testing Lab
 Hoshiarpur

For Regional Water Testing Lab
 Hoshiarpur.

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

S.A.V. Jain Day Boarding School
Una Road, Hoshiarpur


No.: RWTLHSP/2526/00762 Dated : 16/02/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SAV/10252 Dated: 13/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 14/02/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report


Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

For Regional Water Testing Laboratory
Hoshiarpur.

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

Payment Receipt

Receipt No. : 31263

Date : 14/02/2026

Invoice No. : INV/2526/00762

Invoice Date : 14/02/2026


Received From : S.A.V. Jain Day Boarding School
Una Road, Hoshiarpur

The Sum of Rupees : Three Hundred Ninety Eight Only.

In Cash

Rs. : 398.00

Disclaimer: - Payment made by cheque/online mode are subject to clearance by bank.


For Regional Water Testing Laboratory
Hoshiarpur.

For Regional Water Testing Lab, Hoshiarpur
Authorized Signatory

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com


| | | | | | |
|----|----------------------------------|--------|--|----|----------|
| 14 | Bacteriological Contamination(B) | ABSENT | | -- | H2S Vial |
|----|----------------------------------|--------|--|----|----------|

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

For Regional Water Testing Laboratory
Hoshiarpur.


Abhishek Joshi
Sr. Chemist
Authorized Signatory
For,Regional Water Testing Lab
Hoshiarpur

----- End of the Test Report -----