

# REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur  
rwtlhsp@gmail.com


## TEST REPORT

Name & Address of Customer : <b>S.A.V. Jain Day Boarding School Una Road, Hoshiarpur</b>	Customer Reference No.	No : SAV/10252 Dated : 13/02/2026
	Sample Submitted by	Pawan Kumar
	Date of Sample Receipt	14/02/2026
	Analysis Starting Date	14/02/2026
	Analysis completion Date	16/02/2026
Discipline : <b>Chemical Testing, Bacteriological Testing</b>	Group: <b>Water</b>	
UIR No.:	Sample Type :	Water
Test Report No.: <b>RWTLHSP/2526/00762</b>	Date of Issue :	16/02/2026
Registration no.: <b>RWTLHSP/REG2526/04816</b>	Condition of Sample :	Unsealed
Collection Point: <b>Treatment Plant (RO/CWPP/ARP/HH Purifier)</b>	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source: <b>Not Mentioned(Not Mentioned)</b>	Location/Depth :	S.A.V. Jain Day Boarding School / NA
Village : <b>Not Mentioned</b>	Habitation :	Not Mentioned
Block: <b>Hoshiarpur-II</b>	District :	Hoshiarpur
Latitude : <b>Not Mentioned</b>	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.51@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	344.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDI	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	<b>282.8</b>	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	<b>246.44</b>	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2023) EDTA Method
9	Calcium(Ca)	51.82	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	28.47	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	22.15	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
12	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
13	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

Continue on next page...

Reviewed and Approved By

  
**Abhishek Joshi**  
 Sr. Chemist  
 Authorized Signatory  
 For, Regional Water Testing Lab  
 Hoshiarpur

# REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur  
rwtlhsp@gmail.com

To,

S.A.V. Jain Day Boarding School  
Una Road, Hoshiarpur


No.: RWTLHSP/2526/00762 Dated : 16/02/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SAV/10252 Dated: 13/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 14/02/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

D/A : Test Report

  
Authorized Signatory  
For, Regional Water Testing Lab  
Hoshiarpur

# REGIONAL WATER TESTING LAB, HOSHIARPUR


Government ITI, Jalandhar Road, Hoshiarpur  
rwtlhsp@gmail.com

14	Bacteriological Contamination(B)	ABSENT				H2S Vial
----	----------------------------------	--------	--	--	--	----------

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

  
Abhishek Joshi  
Sr. Chemist  
Authorized Signatory  
For,Regional Water Testing Lab  
Hoshiarpur

----- End of the Test Report -----